

ANNUAL REPORT FOR THE HAMLET OF WHALE COVE

YEAR BEING REPORTED: 2009

The following information is compiled pursuant to the requirements of **Part B, Item 1** of Water Licence #3BM-WHA0914 issued to the Hamlet of Whale Cove.

- i) - iii) tabular summaries of all data generated under the “Monitoring Program”; monthly and annual quantities in cubic metres of freshwater obtained from all sources; monthly and annual quantities in cubic metres of each and all wastes discharged;

Attached are quantities of water used as reported in our On Tap Water Delivery System and the estimated discharge of sewage waste based on quantities used.

Month Reported	Quantity of Water Obtained from all sources (m³)	Quantity of Sewage Waste Discharged (Estimated)
January	1,256.3321	Same
February	1,019.8618	Same
March	1,162.8654	Same
April	1,143.7254	Same
May	1,056.1891	Same
June	1,056.4187	Same
July	1,140.1038	Same
August	1,176.2369	Same
September	1,131.0973	Same
October	781.3856	Same
November	1,114.2367	Same
December	944.1033	Same
ANNUAL TOTAL	12,982.5561	Same

Note: There is no meter existing at the Sewage discharge pipe. Therefore the monthly discharge volume is considered as equal to the monthly water consumption volume.

ANNUAL REPORT FOR THE HAMLET OF WHALE COVE

- iv. a summary of modifications and/or major maintenance work carried out on the Water Supply and Waste Disposal Facilities, including all associated structures and facilities;
-
- No modifications/major work carried out in 2009.
- v. a list of unauthorized discharges and summary of follow-up action taken;
-
- 09-247, 04-17-2009, Unit 96D (now 215B), 500L Heating Fuel P50: A new tank has been installed and the area cleaned up of contaminated snow and gravel. Material was disposed inside the bermed area at the dump.
 - 09-248, 05-21-2009, House 95B, 200L Heating Fuel P50: Hamlet loader was used to scrape up contaminated snow and whatever gravel could be removed from the site. The heating fuel tank has been emptied and isolated from the other tank.
 - 09-491, 10-30-2009, behind Health Centre, 30-40L Heating Fuel P50: The contaminated snow and ground has been removed and disposed in the bermed area of the Hamlet. A newer fuel truck is being used.
- vi. a summary of any abandonment and restoration work completed during the year and an outline of any work anticipated for the next year;
-
- No abandonment and restoration work took place in 2009 and none is planned for 2010.
- vii. a summary of any studies requested by the Board that relate to waste disposal, water use or reclamation, and a brief description of any future studies planned;
-
- NWB requested submission of the Solid Waste Disposal Facilities Update Report by October 31, 2009.
- viii. any other details on water use or waste disposal requested by the Board by November 1st of the year being reported; and
-
- N/A
-

ANNUAL REPORT FOR THE HAMLET OF WHALE COVE

ix. updates or revisions to the approved Operation and Maintenance Plans.

- NWB requested submission of updated consolidated Operations and Maintenance (O&M) Manual.
- NWB requested submission of Quality Assurance/Quality Control (QA/QC) Plan.

ADDITIONAL INFORMATION THAT THE LICENSEE DEEMS USEFUL:

- N/A

FOLLOW-UP REGARDING INSPECTION/COMPLIANCE CONCERNS:

- AANDC Inspection Report advised the Hamlet to immediately decant the lagoon.
- AANDC Inspection Report reminded Hamlet of requirement to install flow measurement device on the freshwater pumping station.