

WATER USE INSPECTION REPORT

| | |
|---|---|
| Date: July 31 st , 2008 | Licensee Rep. (Name/Title): Mr. Guy Enuapik – Hamlet Foreman |
| Licensee: Hamlet of Whale Cove | Licence No.: NWB3WHA0207 (Expired) |

WATER SUPPLY

| | |
|---|--|
| Source(s): Fish Lake | Quantity used: Unknown – Records incomplete |
| Owner:/Operator: Government of Nunavut | Treatment systems operated by C&GS , GN |

Indicate: **A** - Acceptable **U** - Unacceptable **NA** - Not Applicable **NI** - Not Inspected

| | | | |
|-----------------------------|-----------------------------|-----------------------------|-----------------------------|
| Intake Facilities: A | Storage Structure: A | Treatment Systems: A | Chemical Storage: NI |
| Flow Meas. Device: U | Conveyance Lines: A | Pumping Stations: A | Screen : NI |

Comments: The Government of Nunavut, Dept. of Community and Government Services provides the oversight and drinking water treatment services for the community. Chlorine reservoir was nearly empty during period of Inspection and Pump house floor was covered with dead flies. Records were on site.

WASTE DISPOSAL

Sewage: Sewage Treatment System (Prim./Sec/Ter.): Primary cell and wetlands treatment

| | | |
|--------------------------------------|--|---------------------|
| Natural Water Body: No | Continuous Discharge (land or water): seepages | |
| Seasonal Discharge: Decanting | Wetlands Treatment: Y | Trench: None |

Solid Waste: Non-combustible waste consolidated at waste metals area.

Owner/Operator: Hamlet of Whale Cove

| | | |
|--------------------------------------|-------------------------------|---------------|
| Landfill: A- some segregation | Burn & Landfill: A | Other: |
|--------------------------------------|-------------------------------|---------------|

Indicate: **A** - Acceptable **U** - Unacceptable **NA** - Not Applicable **NI** - Not Inspected

| | | |
|------------------------------------|---|------------------------|
| Discharge Quality: U | Decant Structure: NI | Erosion: A |
| Discharge Meas. Device: NA | Dyke Inspection: NA | Seepages: U |
| Dams, Dykes: NI | Freeboard: A | Spills: A |
| Construction: NI | O&M Plan: U | A&R Plan: U |
| Periods of Discharge: Cont. | Effluent Discharge Rate: Unknown | |

Comments: Sampled discharge from Waste metals area and Lagoon seepage.

FUEL STORAGE:.

Waste Oil Storage: None noted

Owner/Operator: Nunavut Power Corp.

Indicate: **A** - Acceptable **U** - Unacceptable **NA** - Not Applicable **NI** - Not Inspected

| | | |
|-------------------------------|---|------------------------------|
| Berms & Liners: NI | Water within Berms: NI | Evidence of Leaks: NI |
| Drainage Pipes: NI | Pump Station & Catchments Berm: NI | |
| Pipeline Condition: NI | Condition of Tanks: NI | |

SURVEILLANCE NETWORK PROGRAM (SNP)

| | | |
|---|------------------|--|
| Samples Collected: 0 | | Owner /Operator: No samples from Municipality have been submitted |
| Samples Collected: 3 | | INAC: Potable- Lake, Effluent discharge, Dump Leachate |
| Signs Posted | SNP: None | Warning: Some signs were noted |
| Records & Reporting: No records of water usage, waste discharge. | | |
| Geotechnical Inspection: N/A | | |

Non-Compliance of Act or Licence: The Hamlet of Whale Cove does not currently have a water license. The Municipality is currently in contravention of the Act. The Community has not been collecting samples nor filing the required paperwork. The Municipality was advised to contact the Nunavut Water Board as soon as possible to process an application.

A.Keim

Inspector's Name

Sent by E-mail

Inspector's Signature