

C.O.C.: ---

REPORT No. B13-28163

Report To:

Hamlet of Resolute Bay

Government Office,
NU X0A 0V0 Canada

Attention: Rick Goulton

Caduceon Environmental Laboratories

2378 Holly Lane
Ottawa Ontario K1V 7P1
Tel: 613-526-0123
Fax: 613-526-1244

DATE RECEIVED: 25-Oct-13

JOB/PROJECT NO.:


DATE REPORTED: 06-Nov-13

P.O. NUMBER:

SAMPLE MATRIX: Waste Water

WATERWORKS NO.

			Client I.D.	Sewage Truck			
			Sample I.D.	B13-28163-1			
			Date Collected	25-Oct-13			
Parameter	Units	M.D.L.	Reference Method	Date/Site Analyzed			
BOD	mg/L	3	SM 5210B	26-Oct-13/O	164		
Total Suspended Solids	mg/L	3	SM 2540D	30-Oct-13/O	136		
Hardness (as CaCO ₃)	mg/L	1	SM 3120	28-Oct-13/O	81		
Alkalinity(CaCO ₃) to pH4.5	mg/L	5	SM 2320B	28-Oct-13/O	295		
Conductivity @25°C	µmho/cm	1	SM 2510B	25-Oct-13/O	837		
pH @25°C	pH Units		SM 4500H	25-Oct-13/O	7.76		
Nitrite (N)	mg/L	0.1	SM4110C	29-Oct-13/O	< 0.1		
Nitrate (N)	mg/L	0.1	SM4110C	29-Oct-13/O	0.1		
Chloride	mg/L	0.5	SM4110C	29-Oct-13/O	42.7		
Sulphate	mg/L	1	SM4110C	29-Oct-13/O	54		
Total Organic Carbon	mg/L	0.2	EPA 415.1	30-Oct-13/O	19.1		
Ammonia (N)-Total	mg/L	0.01	MOEE 3364	06-Nov-13/O	39.4		
Phenolics	mg/L	0.001	MOEE 3179	29-Oct-13/O	0.208		
Aluminum (total)	mg/L	0.01	SM 3120	28-Oct-13/O	0.74		
Arsenic	mg/L	0.0001	EPA 200.8	28-Oct-13/O	0.0003		
Calcium	mg/L	0.02	SM 3120	28-Oct-13/O	26.5		
Cadmium	mg/L	0.005	SM 3120	28-Oct-13/O	< 0.005		
Cobalt	mg/L	0.005	SM 3120	28-Oct-13/O	< 0.005		
Copper	mg/L	0.002	SM 3120	28-Oct-13/O	0.067		
Chromium	mg/L	0.002	SM 3120	28-Oct-13/O	0.005		
Iron (Total)	mg/L	0.005	SM 3120	28-Oct-13/O	0.815		
Lead	mg/L	0.02	SM 3120	28-Oct-13/O	< 0.02		
Magnesium	mg/L	0.01	SM 3120	28-Oct-13/O	3.58		
Manganese (Total)	mg/L	0.001	SM 3120	28-Oct-13/O	0.025		
Mercury	mg/L	0.00002	SM 3112 B	29-Oct-13/O	< 0.00002		
Nickel	mg/L	0.01	SM 3120	28-Oct-13/O	< 0.01		
Potassium	mg/L	0.1	SM 3120	28-Oct-13/O	4.1		
Sodium	mg/L	0.2	SM 3120	28-Oct-13/O	28.0		



Gord Murphy
Lab Supervisor

M.D.L. = Method Detection Limit

Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,R-Richmond Hill

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

C.O.C.: ---

REPORT No. B13-28163

Report To:

Hamlet of Resolute Bay

Government Office,
NU X0A 0V0 Canada

Attention: Rick Goulton

Caduceon Environmental Laboratories

2378 Holly Lane
Ottawa Ontario K1V 7P1
Tel: 613-526-0123
Fax: 613-526-1244

DATE RECEIVED: 25-Oct-13

JOB/PROJECT NO.:

DATE REPORTED: 06-Nov-13

P.O. NUMBER:


SAMPLE MATRIX: Waste Water

WATERWORKS NO.

			Client I.D.	Sewage Truck				
			Sample I.D.	B13-28163-1				
			Date Collected	25-Oct-13				
Parameter	Units	M.D.L.	Reference Method	Date/Site Analyzed				
Zinc	mg/L	0.005	SM 3120	28-Oct-13/O	0.076			
Oil & Grease-Total	mg/L	1.0	SM 5520	01-Nov-13/K	31.5			
Fecal Coliform	cfu/100mL	1	MOE E3371	25-Oct-13/O	1600000			

M.D.L. = Method Detection Limit

Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,R-Richmond Hill



Gord Murphy
Lab Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.