



Richard Dwyer <richard.dwyer@nwb-oen.ca>

Amendment: water licence 7BL-AWL2333 for the Arctic Watch Lodge

Monteith, Joseph (he) <joseph.monteith@rcaanc-cirnac.gc.ca>

Thu, Feb 1, 2024 at 10:00 AM

To: Richard Weber <richard@weberarctic.com>, Richard Dwyer <richard.dwyer@nwb-oen.ca>

Cc: "Fraser, Jeremy" <jeremy.fraser@rcaanc-cirnac.gc.ca>, "Pasalic, Omer" <omer.pasalic@rcaanc-cirnac.gc.ca>

Hello Richard,

After seeking consultation with management we have decided that we cannot amend an inspection report to omit a violation of the terms and conditions of your water license. As you are aware, we the Inspectors do ensure the compliance of any Water Licenses that were/are issued by the Water Board. One of those compliance items that we do enforce is having the 31 metres thresholds. Your gray water tanks do fall within the 31 metres thresholds and as such do put your Water License into the non-compliance category.

Unfortunately, as stated above, we cannot amend the direction given at this time.

My recommendation is to seek consultation to remedy your concerns.

Best Regards,

Joseph Monteith

JM

Joseph Monteith

Resource Management Officer

Qikiqtani and High Arctic Region

Crown-Indigenous Relations

And Northern Affairs Canada

P.O. Box 2200

Iqaluit, NU

X0A 0H0

Ph: 867 975-4289

Cell: 867 975-1787

Fax: 867 979-6445

Email: joseph.monteith@canada.ca



Crown-Indigenous Relations
and Northern Affairs Canada

Relations Couronne-Autochtones
et Affaires du Nord Canada

This e-mail and any attachments may contain confidential and privileged information. If you are not the intended recipient, please notify the sender immediately by return e-mail, delete this e-mail and destroy any copies. Any dissemination or use of this information by a person other than the intended recipient is unauthorized and may be illegal.

From: Richard Weber <richard@weberarctic.com>

Sent: Wednesday, January 31, 2024 4:11 PM

To: Richard Dwyer <richard.dwyer@nwb-oen.ca>

[Quoted text hidden]

[Quoted text hidden]