



NWB Tools

Richard Dwyer &lt;richard.dwyer@nwb-oen.ca&gt;

**Fwd: Fed Inspection. 7BL-AWL2333**

Richard Weber <richard@arcticwatch.ca>  
To: Nunavut Water Board <licensing@nwb-oen.ca>

Sat, Jul 22, 2023 at 7:27 AM

Hello Water Board,

We had an inspection at Arctic Watch Lodge from the Environment Canada representative. There were 3 items that were observed.

1. We again had problems with our water meter.
2. Provide drip catchment at fueling points
3. A puddle of water that was less than 31 meters from our main fuel berm.

We have/ will remedy these issues.

1. Attached is a photo of the new water meter and the log. The new meter seems to be much more precise than the old one.
2. Three kid pools for the drips at the filling locations have been purchased and will be installed shortly.
3. The puddle is part of the airstrip drainage. It is almost dry now we will level the surface. We have a quarry permit from QIA, copy attached.

Regards  
Richard Weber

---

**3 attachments**

**AW Water Meter.jpeg**  
252K



**Water Log.jpeg**  
358K



**Quarry Permit.pdf**  
146K