

Average Daily Water Usage at CFS Alert - 8AC-ALT---- (formerly 3BC-ALT1015)

Year [yr]	Month [mo]	Days [day]	Average Daily Intake (Usage) [m3/day]	Maximum Daily Intake [m3/day]	Average Daily Returned [m3/day]	Maximum Daily Return [m3/day]	Average Daily Utilized (Consumed) [m3/day]	Maximum Daily Utilized (Consumed) [m3/day]	Metered [Y/N]	Quantity Utilized [m3]
2017	JAN	31	572	752	489	602	83	288	Y	17,726
2017	FEB	28	575	700	491	571	84	129	Y	16,088
2017	MAR	31	573	709	493	614	80	95	Y	17,774
2017	APR	30	573	742	490	628	83	114	Y	17,199
2017	MAY	31	568	695	486	598	82	109	Y	17,606
2017	JUN	30	542	744	467	672	75	101	Y	16,255
2017	JUL	31	514	609	437	527	76	99	Y	15,926
2017	AUG	31	513	606	425	510	88	462	Y	15,894
2017	SEP	30	534	634	454	549	80	125	Y	16,012
2017	OCT	31	568	671	486	576	83	113	Y	17,622
2017	NOV	30	585	728	505	630	81	462	Y	17,564
2017	DEC	31	430	584	361	495	68	125	Y	13,327
Annual Average [m3/day]:			546	681	465	581	80	185	Total	198,993
Observed Minimum [m3/day]:			430	584	361	495	68	95	Annual	
Observed Maximum [m3/day]:			585	752	505	672	88	462	[m3]:	

Month Jan.		Year 2017												
Day	Raw #1													
	S	TR	Supply				Return					Station	Du	
	PSI	PSI	PSI	Flow m³/d	read m³	total m³	PSI	0°F	Flow m³/d	Read m³	Total m³			
1	15	15	55	624	87,443	585	50	11	510	71327	512	73	2	
2	15	15	57	591	88,081	638	52	12	512	71883	556	82	3	
3	14	15	53	640	88,587	506	47	12	510	72325	442	64	3	
4	15	15	57	583	89,177	590	52	12	506	72835	510	80	3	
5	15	15	55	598	89,782	605	50	12	501	73348	513	92	3	
6	15	14	50	624	90,337	555	46	11	497	73826	478	77	3	
7	14	15	54	592	90,908	571	50	11	500	74,318	492	79	3	
8	15	14	53	615	91,483	575	48	11	494	74,814	496	79	3	
9	14	15	51	624	92,099	616	48	11	222	75,340	526	90	2	
10	14	15	54	611	92,713	614	49	11	517	75,867	527	87	2	
11	14	15	58	558	93,289	576	54	11	466	76,362	495	81	2	
12	14	14	59	552	93,859	570	55	11	477	76,846	484	86	2	
13	14	14	50	658	94,417	558	44	10	518	77,326	480	78	2	
14	13	15	55	590	95,004	587	51	11	483	77,833	507	80	2	
15	14	14	58	578	95,567	563	53	9	476	78,319	486	77	2	
16	13	15	58	563	96,174	607	53	10	486	78,832	513	94	3	
17					96,726	552				79,299	467	85		
18	12	10	51	634	97,278	552	45	10	519	79,765	467	85	3	
19	10	10	56	584	97,941	663	51	10	494	80,332	567	96	3	
20	10	10	56	582	98,463	522	51	10	484	80,776	444	78	3	
21	12	11	50	641	99,108	645	45	11	460	81,330	554	91	3	
22	12	11	56	587	99,579	471	50	11	505	81,735	405	66	3	
23	10	11	52	633	100,200	621	47	11	517	82,242	507	114	3	
24	10	11	59	560	100,921	721	55	11	488	82,843	601	120	2	
25	15	11	51	653	101,349	428	45	12	494	83,218	375	53	2	
26	13	11	53	638	101,799	450	47	11	523	83,779	561	-111	2	
27	12	10	55	598	102,551	752	50	11	511	84,243	464	288	2	
28	13	11	56	596	103,227	676	51	12	513	84,820	577	99	2	
29	12	12	53	612	103,740	513	49	13	504	85,272	452	61	2	
30	12	11	60	551	104,447	707	56	12	486	85,874	602	105	1	
31	13	12	48	638	104,584	137	48	12	519	85,975	101	36	2	
Total						17,726						15,161	2,565	
Avg						604						489	83	
Min						551						101	-111	
Max						658						602	288	

Day	Distribution Loop												
	Raw												
	S	TR	Supply				Return					Station Use m³	Dis
	PSI	PSI	PSI	Flow m³/d	Read m³	Total m³	PSI	0°F	Flow m³/d	Read m³	Total m³		
1	16	17	61	601	105,284	700	52	12	451	86546	571	129	2
2	16	17	59	574	105,768	484	54	13	492	86970	424	60	2
3	16	14	55	597	106,309	541		12	507	87443	473	68	2
4	15	16	57	586	106,868	559	51	12	559	87906	463	96	2
5	15	16	58	564	107,460	592	52	12	509	88416	510	82	2
6	15	16	57	574	108,078	618	51	13	474	88953	537	81	3
7	16	17	51	619	108,655	577	46	13	512	89,447	494	83	3
8	16	17	58	547	109,181	526	54	12	482	89,905	458	68	3
9	16	16	52	594	109,810	629	49	12		90,431	526	103	3
10	15	15	56	610	110,374	564	53	12	471	90,918	487	77	3
11	15	16	55	602	110,900	526	51	12	478	91,351	433	93	3
12	15	16	57	561	111,450	550	52	13	497	91,824	473	77	3
13	15	16	54	612	112,103	653	45	12	508	92,381	557	96	2
14	15	16	53	616	112,700	597	48	12	503	92,892	511	86	2
15	15	16	55	600	113,267	567	50	12	490	93,381	489	78	2
16	15	15	50	585	113,867	600	51	11	504	93,895	514	86	2
17	16	17	53	613	114,424	557	47	12	496	94,377	482	75	2
18	15	15	51	572	114,943	519	53	12	499	94,829	452	67	2
19	14	15	57	561	115,528	585	52	11	495	95,335	506	79	2
20	15	16	54	591	116,191	663	49	11	530	95,903	568	95	3
21	16	17	59	586	116,718	527	52	11	468	96,366	463	64	3
22	15	16	59	587	117,271	553	52	11	458	96,834	468	85	3
23	15	16	54	605	117,821	550	50	14	458	97,309	475	75	3
24	15	16	54	578	118,377	556	50	11	460	97,787	478	78	3
25	16	16	57	570	118,909	532	53	10	472	98,224	437	95	3
26	16	17	56	578	119,440	531	51	10	463	98,673	449	82	3
27	15	16	55	574	120,106	666	52	10	464	99,230	557	109	2
28	15	16	56	570	120,672	566	52	11	490	99,721	491	75	2
29													
30													
31													
Total						16,088						13,746	2,342
Avg						587						491	84
Min						547						424	60
Max						619						571	129

Month Mar		Year 2017				Mar-15								
Day	Raw #1		Distribution Loop #2										Station	D
	S	TR	Supply				Return							
	PSI	PSI	PSI	Flow m³/d	Read m³	Total m³	PSI	0°F	Flow m³/d	Read m³	Total m³			
1	16	17	58	580	121,226	554	53	11	481	100199	478	76	2	
2	16	17	57	599	121,798	572	52	11	471	100685	486	86	2	
3	16	17	57	567	122,374	576	53	11	482	101178	493	83	2	
4	16	17	61	547	122,841	467	56	12	478	101585	407	60	2	
5	15	16	60	557	123,398	557	55	12	481	102066	481	76	2	
6	14	16	57	597	124,038	640	55	11	466	102613	547	93	3	
7	15	16	57	617	124,605	567	46	11	506	103,101	488	79	3	
8	15	16	55	588	125,176	571	51	11	471	103,586	485	86	3	
9	15	16	57	573	125,736	560	53	11	477	104,067	481	79	3	
10	15	16	54	587	126,293	557	47	11	470	104,544	477	80	3	
11	15	16	58	557	126,798	505	51	2	482	104,980	436	69	3	
12	15	16	58	571	127,358	560	52	11	479	105,455	475	85	3	
13	15	16	56	566	127,963	605	51	11	480	105,971	516	89	2	
14	15	16	53	610	128,549	586	51	11	496	106,474	503	83	2	
15	15	16	53	618	129,128	579	47	11	484	106,970	496	83	2	
16	16	17	57	568	129,707	579	52	11	496	107,466	496	83	2	
17	16	17	57	573	130,279	572	52	11	496	107,957	491	81	2	
18	16	17	58	560	130,800	521	53	11	496	108,409	452	69	2	
19	14	14	57	573	131,359	559	53	11	492	108,893	484	75	2	
20	16	17	54	603	131,999	640	49	11	500	109,441	548	92	3	
21	17	18	51	624	132,587	588	46	11	496	109,953	512	76	3	
22	17	19	53	602	133,164	577	48	11	508	110,455	502	75	3	
23	16	17	53	578	133,783	619	48	11	505	110,985	530	89	3	
24	16	17	53	609	134,363	580	48	11	500	111,485	500	80	3	
25	15	16	54	583	134,877	514	49	11	500	111,927	442	72	3	
26	17	18	52	617	135,489	612	47	11	496	112,458	531	81	3	
27	14	15	51	607	136,101	612	46	11	493	112,981	523	89	2	
28	14	16	57	581	136,712	611	52	11	511	113,502	521	90	2	
29	16	17	56	578	137,143	431	51	11	503	113,877	375	56	2	
30	14	16	55	579	137,852	709	51	11	504	114,491	614	95	2	
31	14	15	54	597	138,446	594	50	11	500	115,003	512	82	2	
Total						17,774						15,282	2,492	
Avg						586						493	80	
Min						547						466	375	56
Max						624						511	614	95

Day	Raw #1		Distribution Loop #2										
	S	TR	Supply				Return					Station Use m³	Duty HL
	PSI	PSI	PSI	Flow m³/d	Read m³	Total m³	PSI	0°F	Flow m³/d	Read m³	Total m³		
1	15	52	57	575	139,008		52	12	501	115490	487	-487	2
2	14	49	55	603	139,668	660	50	12	496	116057	567	93	2
3	14	51	53	607	140,164	496	48	12	525	116491	434	62	3
4	15	54	52	604	140,736	572	48	12	502	116978	487	85	3
5	13	50	52	624	141,336	600	46	12	502	117493	515	85	3
6	14	53	53	591	141,933	597	48	12	507	118009	516	81	3
7	14	55	55	591	142,534	601	49	12	507	118,531	522	79	3
8	14	55	55	573	143,099	565	50	12	505	119,029	498	67	3
9	14	53	54	588	143,688	589	50	12	504	119,543	514	75	3
10	14	53	56	566	144,295	607	52	12	484	120,069	526	81	2
11	14	55	53	521	144,827	532	49	11	444	120,525	456	76	2
12	14	45	45	609	145,315	488	40	12	489	120,946	421	67	2
13	15	52	48	562	145,874	559	45	12	472	121,427	481	78	2
14	14	55	49	565	146,430	556	45	12	451	121,898	471	85	2
15	14	55	49	564	146,976	546	45	12	449	122,361	463	83	2
16	15	52	50	555	147,554	578	46	12	447	122,833	472	106	2
17	14	55	49	564	148,080	526	46	12	424	123,282	449	77	3
18	14	56	56	570	148,640	560	52	12	485	123,756	474	86	3
19	14	58	57	555	149,228	588	53	13	479	124,256	500	88	3
20	14	55	54	582	149,903	675	50	12	505	124,825	569	106	3
21	14	54	54	589	150,353	450	49	12	494	125,211	386	64	3
22	14	54	54	595	150,914	561	49	13	498	125,699	488	73	3
23	14	47	47	681	151,567	653	42	12	471	126,250	551	102	3
24	14	48	48	666	152,181	614	45	13	524	126,776	526	88	2
25	14	60	56	592	152,690	509	52	12	498	127,210	434	75	2
26	13	52	55	619	153,302	612	51	12	491	127,724	514	98	2
27	13	52	53	622	154,044	742	49	12	491	128,352	628	114	2
28	13	54	54	611	154,490	446	49	12	493	128,735	383	63	2
29	14	52	53	616	155,038	548	49	12	484	129,200	465	83	2
30	14	52	54	615	155,634	596	49	12	489	129,699	499	97	2
31													
Total						16,626					14,696	1,930	
Avg			593			573			487		490	64	
Min			521			446			424		383	-487	
Max			681			742			525		628	114	

Day	Raw ^{*1}		Distribution Loop ^{*2}										
	S	TR	Supply				Return					Station	Duty HL
	PSI	PSI	PSI	Flow m³/d	Read m³	Total m³	PSI	0°F	Flow m³/d	Read m³	Total m³	Use m³	
1	14	57	57	591	156,226	592	52	13	468	130197	498	94	3
2	14	53	53	615	156,840	614	48	12	494	130718	521	93	3
3	14	52	52	597	157,443	603	48	13	495	131215	497	106	3
4	18	53	53	593	157,958	515	49	13	497	131657	442	73	3
5	17	52	52	616	158,612	654	47	13	488	132213	556	98	3
6	15	53	53	625	159,172	560	49	13	484	132697	484	76	3
7	15	54	55	577	159,698	526	51	13	485	133,151	454	72	3
8	14	55	55	602	160,254	556	50	14	478	133,631	480	76	2
9	14	52	59	534	160,860	606	54	14	482	134,149	518	88	2
10	14	54	54	582	161,386	526	49	14	476	134,629	480	46	2
11	13	52	55	579	161,984	598	50	14	497	135,118	489	109	2
12	14	52	51	616	162,548	564	47	14	493	135,613	495	69	2
13	13	51	53	605	163,126	578	50	14	491	136,116	503	75	2
14	13	54	57	551	163,670	544	53	14	494	136,591	475	69	2
15	12	58	53	579	164,254	584	49	14	497	137,102	511	73	3
16	14	54	54	581	164,859	605	49	14	490	137,624	522	83	3
17	13	54	53	591	165,398	539	49	14	486	138,092	468	71	3
18	14	52	57	557	166,013	615	52	14	495	138,630	538	77	3
19	12	53	54	577	166,528	515	50	13	484	139,073	443	72	3
20	13	53	53	591	167,076	548	49	13	485	139,540	467	81	3
21	14	56	52	593	167,666	590	48	13	476	140,035	495	95	2
22	15	52	51	613	168,215	549	46	13	515	140,506	471	78	2
23	16	55	57	565	168,741	526	52	13	473	140,945	439	87	2
24	16	17	56	561	169,348	607	52	14	463	141,459	514	93	3
25	16	17	53	588	169,913	565	51	14	487	141,938	479	86	2
26	16	17	56	590	170,509	596	51	15	485	142,448	510	86	2
27	16	17	57	588	171,010	501	53	14	479	142,872	424	77	2
28	16	17	57	576	171,705	695	53	14	470	143,470	598	97	2
29	16	17	59	551	172,169	464	55	14	462	143,854	384	80	3
30	16	16	57	576	172,733	564	52	14	460	144,333	479	85	3
31	15	16	55	577	173,240	507	51	14	486	144,766	433	74	3
Total												15,067	2,539
Avg			585									486	82
Min			534									384	46
Max			625									598	109

Day	Raw #1		Distribution Loop #2										
	S	TR	Supply				Return					Station	Duty HL
	PSI	PSI	PSI	Flow m ³ /d	Read m ³	Total m ³	PSI	0 ^F	Flow m ³ /d	Read m ³	Total m ³	Use m ³	
1	14	15	57	546	189,928	433	53	13	487	159134	373	60	3
2	14	15	57	541	190,537	609	53	14	487	159656	522	87	2
3	15	15	53	497	191,062	525	48	13	433	160103	447	78	2
4	17	18	49	548	191,614	552	45	13	404	160556	453	99	2
5	17	18	49	554	192,102	488	45	13	435	160963	407	81	2
6	16	17	49	497	192,612	510	46	14	416	161402	439	71	2
7	16	17	48	510	193,052	440	44	14	429	161,770	368	72	2
8	15	16	48	526	193,563	511	44	15	451	162,199	429	82	2
9	17	17	47	508	194,095	532	44	15	148	162,641	442	90	2
10	16	17	47	510	194,644	549	44	15	430	163,104	463	86	2
11	16	17	50	490	195,099	455	47	15	448	163,478	374	81	2
12	12	13	52	475	195,574	475	46	16	459	163,864	386	89	2
13	17	18	50	453	196,157	583	45	14	418	164,391	527	56	2
14	18	19	49	535	196,678	521	45	12	428	164,847	456	65	2
15	18	19	49	518	197,129	451	44	13	463	165,224	377	74	2
16	15	16	48	520	197,648	519	45	14	430	165,665	441	78	2
17	16	17	45	506	198,211	563	45	14	450	166,145	480	83	2
18	18	19	48	523	198,739	528	44	14	444	166,594	449	79	2
19	16	17	48	507	199,166	427	45	13	431	166,964	370	57	124
20	14	17	46	541	199,761	595	42	13	410	167,464	500	95	2
21	15	19	48	517	200,301	540	42	13	441	167,926	462	78	2
22	15	17	48	516	200,780	479	44	13	436	168,344	418	61	2
23	15	17	47	529	201,315	535	43	14	423	168,799	455	80	2
24	15	14	48	514	201,803	488	44	14	436	169,223	424	64	2
25	17	15	47	519	202,356	553	44	15	435	169,679	456	97	2
26	56	15	42	563	202,812	456	39	14	406	170,064	385	71	2
27	16	17	47	533	203,395	583	43	14	416	170,556	492	91	2
28	55	15	49	507	203,936	541	45	14	425	171,023	467	74	2
29	14	17	17	529	204,401	465	43	15	442	171,429	406	59	2
30	55	15	47	528	204,915	514	43	15	452	171,878	449	65	2
31	54	15	49	509	205,421	506	45	158	448	172,321	443	63	2
Total						15,926					13,560	2,366	
Avg			518			514			428		437	76	
Min			453			427			148		368	56	
Max			563			609			487		527	99	

NOTE: Flow Meters N/S

Day	Raw ^{*1}		Distribution Loop ^{*2}										
	S	TR	Supply				Return					Station	Duty HL
	PSI	PSI	PSI	Flow m ³ /d	Read m ³	Total m ³	PSI	0 ^F	Flow m ³ /d	Read m ³	Total m ³	Use m ³	
1	15	19	48	503	205,932	506	45	15	439	172768	44	462	2
2	15	19	48	502	206,442	510	45	14	445	173212	444	66	2
3	13	16	47	523	206,952	510	43	14	423	173659	447	63	2
4	14	15	50	485	207,456	504	45	15	488	174124	465	39	2
5	13	15	49	494	207,945	489	45	15	441	174540	416	73	2
6	14	19	17	522	208,464	519	43	15	418	174988	448	71	2
7	16	19	19	470	208,910	446	45	15	444	175,384	396	50	2
8	14	17	17	522	209,433	523	43	15	414	175,841	457	66	2
9	15	17	17	520	209,936	503	43	15	429	176,264	423	80	2
10	14	18	18	501	210,436	500	44	14	431	176,701	437	63	2
11	14	17	47	515	210,939	503	43	15	431	177,127	426	77	2
12	13	17	47	510	211,455	516	43	15	459	177,575	448	68	2
13	12	19	43	547	212,002	547	43	15	422	178,054	479	68	2
14	13	17	45	534	212,489	487	41	15	421	178,479	425	62	2
15	13	19	45	527	213,042	553	42	15	415	178,947	468	85	2
16	13	15	45	528	213,518	476	42	16	409	179,359	412	64	2
17	13	17	48	499	214,017	499	44	15	429	179,780	421	78	2
18	15	17	47	506	214,517	500	43	16	454	180,216	436	64	2
19	14	15	48	488	215,032	515	45	16	445	180,647	431	84	2
20	13	17	47	511	215,525	493	44	16	412	181,066	419	74	2
21	15	18	44	534	216,020	495	41	15	398	181,474	408	87	2
22	15	17	45	525	216,531	511	42	15	409	181,894	420	91	2
23	13	16	47	508	217,052	521	43	15	429	182,331	437	84	2
24	13	18	48	482	217,570	518	37	15	163	182,757	426	92	2
25	14	16	47	496	218,049	479	44	15	426	183,159	402	77	2
26	15	18	45	521	218,565	516	42	14	423	183,590	431	85	2
27	16	19	43	536	219,130	565	41	14	395	184,047	457	108	2
28	14	16	44	545	219,567	437	41	15	394	184,414	367	70	2
29	14	18	50	622	220,173	606	46	13	473	184,924	510	96	2
30	13	19	56	574	220,726	553	51	14	484	185,396	472	81	2
31	14	17	54	595	221,320	594	49	14	488	185,899	503	91	2
Total						15,894					13,175	2,719	
Avg				521		513			424		425	88	
Min				470		437			163		44	39	
Max				622		606			488		510	462	

NOTE: Flow Meters N/S

Day	Raw ^{*1}		Distribution Loop ^{*2}										
	S	TR	Supply				Return					Station	Duty HL
	PSI	PSI	PSI	Flow m ³ /d	Read m ³	Total m ³	PSI	0 ^F	Flow m ³ /d	Read m ³	Total m ³	Use m ³	
1	14	15	52	559	237,900	568	48	19	458	200046	486	82	3
2	14	15	53	581	238,503	603	51	12	444	200557	511	92	3
3	14	15	53	568	239,061	558	49	12	453	201034	477	81	3
4	15	15	55	575	239,594	533	50	11	456	201484	450	83	2
5	14	14	55	579	240,191	597	51	11	478	201986	502	95	2
6	16	17	55	579	240,760	569	50	11	500	202471	485	84	2
7	15	16	58	545	241,215	455	53	12	490	202,864	393	62	2
8	14	15	57	544	241,811	596	53	12	488	203,378	514	82	2
9	14	15	57	579	242,362	551	53	11	476	203,869	491	60	3
10	14	15	57	579	242,985	623	52	12	491	204,393	524	99	3
11	14	15	57	555	243,585	600	52	12	490	204,907	514	86	3
12	14	15	57	549	244,124	539	52	12	491	205,375	468	71	3
13	14	15	54	601	244,708	584	50	12	466	205,873	498	86	3
14	15	15	57	555	245,190	482	53	13	489	206,289	416	66	3
15	14	14	52	634	245,769	579	47	12	531	206,785	496	83	3
16	14	15	55	595	246,440	671	51	13	483	207,361	576	95	2
17	15	16	58	574	246,996	556	54	12	481	207,839	478	78	2
18	15	16	57	578	247,575	579	52	12	500	208,330	491	88	2
19	14	15	52	625	248,162	587	49	12	472	208,835	505	82	2
20	15	16	55	582	248,740	578	52	12	471	209,326	491	87	2
21	14	15	58	562	249,175	435	54	12	472	209,697	371	64	2
22	14	15	58	531	249,776	601	56	12	483	210,211	514	87	2
23	15	15	58	733	250,409	633	54	12	454	210,731	520	113	2
24	14	14	57	574	250,966	557	52	12	477	211,201	470	87	3
25	14	17	55	597	251,534	568	50	11	462	211,696	495	73	3
26	14	14	56	562	252,107	573	51	12	453	212,192	496	77	3
27	13	14	54	581	252,670	563	50	12	467	212,643	451	112	3
28	14	15	56	580	253,186	516	51	12	471	213,080	437	79	3
29	13	14	56	571	253,733	547	52	11	483	213,554	474	73	3
30	15	16	58	586	254,377	644	53	11	468	214,106	552	92	2
31	16	16	59	555	254,954	577	54	11	497	214,624	518	59	2
Total						17,622					15,064	2,558	
Avg			580			568			477		486	83	
Min			531			435			444		371	59	
Max			733			671			531		576	113	

Day	Raw *1		Distribution Loop *2										
	S	TR	Supply				Return					2	Duty HL
	PSI	PSI	PSI	Flow m³/d	Read m³	Total m³	PSI	0°F	Flow m³/d	Read m³	Total m³		
1	15	16	57	601	255,511	557	51	11	513	215090	466	91	2
2	16	17	56	580	256,163	652	50	12	515	215645	555	97	2
3	15	16	55	622	256,720	557	49	12	568	216142	497	60	2
4	15	16	54	609	257,215	495	49	11	514	216572	430	65	2
5	14	15	54	605	257,844	629	50	11	512	217122	550	79	2
6	14	15	52	616	258,492	648	46	11	519	217690	568	80	3
7	14	15	54	603	259,092	600	48	11	507	218,214	524	76	3
8	14	14	53	611	259,671	579	48	12	507	218,715	501	78	3
9	14	15	51	631	260,274	603	46	11	508	219,245	530	73	3
10	17	18	56	574	260,862	588	52	11	482	219,741	496	92	3
11	16	17	57	556	261,301	439	53	12	491	220,126	385	54	3
12	14	14	54	594	261,855	554	49	12	530	220,606	480	74	3
13	14	15	57	581	262,498	643	53	12	491	221,162	556	87	2
14	15	16	57	560	263,148	650	54	12	498	221,719	557	93	2
15	15	15	54	595	263,637	489	50	12	513	222,144	425	64	2
16	15	16	55	598	264,365	728	50	12	514	222,774	630	98	2
17	15	15	55	609	264,923	558	50	12	512	223,256	482	76	2
18	15	15	54	628	265,515	592	45	12	514	223,770	514	78	2
19	14	15	56	587	266,089	574	51	12	506	224,269	499	75	2
20	16	14	51	592	266,725	636	46	12	500	224,814	545	91	3
21	14	14	53	579	267,286	561	48	12	490	225,292	478	83	3
22	14	14	45	656	267,832	546	40	12	487	225,757	465	81	3
23	16	15	47	634	268,423	591	43	12	469	226,252	495	96	3
24	14	14	49	611	269,029	606	45	12	486	226,761	509	97	3
25	16	14	49	611	269,568	539	46	12	492	227,226	465	74	3
26	14	15	53	570	270,164	596	48	12	517	227,740	514	82	3
27	16	14	51	596	270,756	592	46	12	506	228,253	513	79	1
28	15	14	52	630	271,351	595	47	12	502	228,766	513	82	1
29	14	14	53	599	271,965	614	49	12	229	229,294	528	86	1
30	16	14	53	622	272,518	553	48	12	498	229,769	475	78	1
Total						17,564						15,145	2,419
Avg						602						505	81
Min						556						385	54
Max						656						630	98

Day	Raw *1		Distribution Loop *2										
	S	TR	Supply				Return					Station	Duty HL
	PSI	PSI	PSI	Flow m³/d	Read m³	Total m³	PSI	0°F	Flow m³/d	Read m³	Total m³	Use m³	
1	14	16	55	596	273,099	581	50	12	500	230272	503	78	1
2	15	16	50	582	273,602	503	50	12	500	230792	520	-17	1
3	14	16	56	576	274,305	703	51	12	510	231312	520	183	1
4	14	14	57	574	274,862	557	53	13	511	231793	481	76	2
5	16	15	54	597	275,434	572	49	13	494	232290	497	75	2
6	14	15	53	591	276,014	580	50	13	496	232790	500	80	2
7	14	15	55	580	276,657	643	50	12	498	233,344	554	89	2
8	15	16	54	589	277,195	538	49	12	499	233,812	468	70	2
9	16	15	57	564	277,759	564	52	12	502	234,300	488	76	2
10	14	15	56	573	278,341	582	51	12	500	234,805	505	77	2
11	16	14	56	595	278,924	583	50	13	494	235,302	497	86	3
12	14	16	48	613	279,509	585	44	12	498	235,804	502	83	3
13	16	15	52	586	280,072	563	47	12	496	236,286	482	81	3
14	14	14	53	601	280,672	600	47	12	498	236,805	519	81	3
15	15	16	53	583	281,269	597	48	12	481	237,320	515	82	3
16	14	16	53	566	281,817	548	49	13	485	237,799	479	69	3
17	16	15	50	591	282,386	569	46	12	472	238,296	497	72	3
18	14	14	57	578	282,884	498	52	12	496	238,727	431	67	1
19	16	16	14	596	283,479	595	49	12	507	239,242	515	80	1
20	14	16	54	581	284,106	627	50	12	508	239,781	539	88	1
21	16	15	51	638	284,703	597	46	12	496	240,303	522	75	1
22	15	16	55	580	285,282	579	50	12	506	240,800	497	82	1
23	14	16	48	653	285,888	606	43	12	487	241,324	524	82	1
24	15	14	57	584	286,446	558	51	12	504	241,807	483	75	1
25	16	16	57	555	286,994	548	53	13	508	242,284	477	71	2
26	16	14	52	615	287,593	599	47	13	524	242,813	529	70	2
27	15	14	52	616	288,229	636	46	13	512	243,373	560	76	2
28	16	14	57	579	288,818	589	52	13	497	243,887	514	75	2
29	16	16	54	577	289,452	634	49	13	503	244,437	550	84	2
30	14	14	59	547	289,961	509	54	13	506	244,883	446	63	2
31	16	15	48	654	290,558	597	43	13	489	245,407	524	73	2
Total						13,327					11,204	2,123	
Avg				434		430			362		361	68	
Min				381		255			340		224	-17	
Max				566		584			409		495	189	