

QUANTITIES OF WASTE WATER DISCHARGED

Eureka 2014

Waste Water: Sewage Lagoon

1. 1 pump capacity:

-Monarch Pump Model TT30 Type E with attached hose ~ 150 gal/min

2. Pump time:

-July decanting began on July 6 and ended July 8

= ~279,000 gal or ~1,056 m³

-Second decanting was on August 3 and ended August 8

= ~108,000 gal or ~409 m³

-Total for both decanting was = ~1,468 m³