

- i. Complete
- ii. Require contact info for Station Manager
- iii. Insufficient information on spill clean-up and containment measures
- iv. Topographical map needs to be part of plan
- v. Complete
- vi. More detailed information required for spills threatening water
- vii. Complete
- viii. Complete
- ix. Partially complete should also include DFO Number; Local or regional health and the RCMP
- x. Spill response scenarios for spills to land, snow, ice and water need to be included
- xi. Will be acceptable if MSDS on site, but that must be confirmed in plan.

GN spill number 867- 920-8130 pg 4
fax 867-873-6924