



P.O. Box 119
GJOA HAVEN, NU X0B 1J0
TEL: (867) 360-6338
FAX: (867) 360-6369

ᓄᓇᓂᓪᓗ ᐃᓕᓕᓂᓪᓗ ᑲᑎᓕᓂᓪᓗ
NUNAVUT IMALIRIYIN KATIMAYINGI
NUNAVUT WATER BOARD
OFFICE DES EAUX DU NUNAVUT

File: 3BC-EUR0611/H1

January 8, 2008

Ms. Natalie Boulanger, P.eng.
Manager, District 3
Acting Head, Major Construction & Recapitalization Program (MCRP)
Environment Canada Property, Management, Environment Canada
335 River Road
Ottawa, ON K1A 0H3
E-mail: Natalie.Boulanger@ec.gc.ca

Subject: Submission of Spill Plan under License 3BC-EUR0611, Part H, Item 1

Dear Ms. Boulanger:

The Nunavut Water Board ("NWB") would like to acknowledge receipt of the above document on November 23, 2007. It should be noted that the Plan was required to be submitted to the NWB within sixty (60) days of issuance of the Licence.

The NWB has conducted a preliminary technical review on *Oil Pollution Emergency Plan for Land Spills* and has determined that the Plan submitted did not comply with several conditions of Part H, Item I of the Licence. Prior to general distribution to interested persons for a formal technical review, the NWB is requesting a resubmission of a revised Plan within thirty (30) days of this notification to address, at a minimum, the following items as required by Part H, Item 1:

General:

- GPS (latitude and longitude) coordinates for the site;
- A site description;
- Update the NU 24-hour Spill Line number to 867-920-8130;
- ii. The name and contact info for the Station Manager;
- iii. More details on specific responses to spills that have potential to enter water bodies;
- iv. A topographical map of suitable scale showing all facilities and spill kits;
- vi. Information on prevention and responses for spill associated with the refueling of equipment and emergency tanks;

- x. Spill response scenarios for spills to land, snow, ice and water;
- xi. MSDSs should be appended to the Plan, and must be kept on site;
- ix. Contact information should include:
 - o DFO - 867-979-8007
 - o Local or Regional Health Officer, Iqaluit – 867-975-4815
 - o RCMP
 - o QIA – 867-979-5359

Additional details are available in the Licence under Part H, Item 1. Should you have any further questions, please feel free to contact the undersigned at dcarr@nunavutwaterboard.org or Phyllis Beaulieu, Manager of Licensing, by telephone, or by email at licensing@nunavutwaterboard.org.

Yours truly,

Original signed by:

Don Carr
Hearing Coordinator
Nunavut Water Board
Gjoa Haven, NU
Phone: 867-360-6338