



P.O. BOX 119
GJOA HAVEN, NU X0B 1J0
TEL: (867) 360-6338
FAX: (867) 360-6369

ᓄᓇᓂᓪ ᐃᓕᓕᓂᓪ ᓅᓂᓕᓂᓪ
NUNAVUT IMALIRIYIN KATIMAYINGI
NUNAVUT WATER BOARD
OFFICE DES EAUX DU NUNAVUT

August 19, 2008

Ms Natalie Boulanger, Manager, District 3
Acting Head, Major Construction & Recapitalization Program (MCRP)
Environment Canada Property, Management, Environment Canada
335 River Road
Ottawa, ON K1A 0H3
Email: Natalie.Boulanger@ec.gc.ca

Subject: Further Addendum to Spill Plan Required

Dear Ms. Boulanger,

The NWB has conducted a review of your addendum to the document entitled “Oil Pollution Emergency Plan for Land Spills” dated February, 2008. After review it was noted that most of the requirements have been acted on, however the Licence does have two unaddressed issues. As the issues are specifically required by the Licence 3BC-EUR0611 under Part H, Item 1 vi. and x. the NWB is unable to accept the February 2008 Plan as complete. Another addendum to address Part H, Item 1 vi., x. and updating contact info as per March 26, 2008 INAC comments is required.

The submitted plan covers significant prevention measures in place, however it does not address any cleanup strategies. A simple description of cleanup methods for spills on snow, water, ice and land would suffice. The NWB is aware the Canadian Coast Guard would be present to clean up any spills during the annual refueling, however the Plan must address spill cleanups as the Coast Guard is not always present. For an example, please see sections 6.1 - 6.4 of “070817 2BB-MRY0710 Spill Contingency Plan August 2007-ILAE.pdf” on the NWB ftp site, /2BB%20-%20BULK%20SAMPLING/2BB-MRY/Spill%20Contingency%20Plan/.

If you have any questions as to what is required by the Board please contact me at (867) 360-6338 ext. 30 or by email at dcarr@nunavutwaterboard.org.

Sincerely,

Original Signed By:

Don Carr
Technical Advisor
Nunavut Water Board