



NWB Tools

Ida Porter <ida.porter@nwb-oen.ca>

FW: FW: 3BC-CAM0919 Amendment Application

Sonia Aredes <sonia.aredes@nwb-oen.ca>

Tue, Nov 10, 2015 at 9:10 AM

To: Ida Porter <ida.porter@nwb-oen.ca>

Cc: Phyllis Beaulieu <phyllis.beaulieu@nwb-oen.ca>

Hi Ida

The Applicant has answered (in some way) the questionnaire submitted by the NWB; I have to check the Applicant info regarding the authorization letter (that is minor); the Board can accept its answer and may move forward with the Application. However, I would like to ask Teresa whether in this case NUPPAA applies or not, because it is an amendment application and the proposed modification is not significant to the Project.

I will email her and let you know how to proceed regarding this application.

Cheers

Sonia

[Quoted text hidden]



NWB Tools

Ida Porter <ida.porter@nwb-oen.ca>

FW: FW: 3BC-CAM0919 Amendment Application

Sonia Aredes <sonia.aredes@nwb-oen.ca>

Tue, Nov 10, 2015 at 1:44 PM

To: IAN.CREIGHTON3@forces.gc.ca

Cc: Ida Porter <ida.porter@nwb-oen.ca>, Licensing Department <licensing@nwb-oen.ca>

Good Afternoon Ian

I have an additional question that needs to be answered in order to decide if the application requires further evaluation.

Is the proposal aimed to have ONLY an annual limit rather than both an annual and daily limit?

The Nunavut Waters Regulations set the thresholds for various types of licences on the basis of daily limits, therefore the nwb would still have to insert a condition in order to ensure the Type B daily threshold of 300 cubic meters per day for water use is not exceeded. The Board can't eliminate this daily limit in the Water licence, this is in order to ensure the licensee does not exceed the maximum threshold for a type B.

If the Applicant's intention is to eliminate the daily limit from the licence, that is a significant change to the Project and that may involve other licensing requirements, like a new application for a new Type A licence rather than a Type B Licence.

Regards

Sonia Aredes

Technical Advisor

NWB

[Quoted text hidden]



NWB Tools

Ida Porter <ida.porter@nwb-oen.ca>

FW: FW: 3BC-CAM0919 Amendment Application

IAN.CREIGHTON3@forces.gc.ca <IAN.CREIGHTON3@forces.gc.ca>

Tue, Nov 10, 2015 at 2:48 PM

To: sonia.aredes@nwb-oen.ca

Cc: ida.porter@nwb-oen.ca, licensing@nwb-oen.ca, william.wyman@raytheon.com, don.beattie@raytheon.com, SCOTT.CHARLAND@forces.gc.ca

Afternoon Sonia,

I understood that licenses were issued with either a daily or an annual limit...but now I know better. All of DND licenses are Type B with an annual limit, except the one at CAM-M which has a daily limit. For consistency, we simply wanted to convert the CAM-M daily limit (10m³/day) to the equivalent annual limit (365 x 10 = 3650 m³/yr). Additionally, DND could run exercises and operations at CAM-M, where a temporary surge in personnel would consume more than 10m³/day but not more than 3650 m³/yr. During the last exercise, the surge consumed less than 30 m³/day (only 10% of the Type B daily threshold). So to answer your question, a Type B license with a daily limit of 300 m³/day and an annual limit of 3650 m³/yr is requested for CAM-M.

Regards and thank-you,

MAJ IAN CREIGHTON, PENG, CD

N.W.S. FACILITIES MANAGER / CF RP OPS GRP / ADM(IE)

CANADIAN ARMED FORCES

Ian.Creighton3@forces.gc.ca / TEL: 819-939-4963 / FAX: 819-939-4868

GESTIONNAIRE DES INSTALLATIONS DE S.A.N. / GRPE DES ACT. IMMOB. DES FC / SMA(IE)

FORCES ARMÉES CANADIENNE

Ian.Creighton3@forces.gc.ca / TEL: 819-939-4963 / FAX: 819-939-4868

From: Sonia Aredes [mailto:sonia.aredes@nwb-oen.ca]

Sent: November-10-15 3:45 PM

To: Creighton Maj IA@ADM(IE) CF RP Ops Gp@Ottawa-Hull

Cc: Ida Porter; Licensing Department

Subject: 3BC-CAM0919 Amendment Application

[Quoted text hidden]