



P.O. Box 119  
GJOA HAVEN, NU X0B 1J0  
TEL: (867) 360-6338  
FAX: (867) 360-6369

ᓇᓇᑦ ልਲᓱᓪᓗᓘ  
NUNAVUT WATER BOARD  
NUNAVUT IMALIRIYIN KATIMAYIT  
OFFICE DES EAUX DU NUNAVUT

---

File: **3BC-EUR0611/TR/B2**

September 19, 2011

Mr. Carl Carroll  
Property Management Divisions Assets  
Contracting & Environ Management Directorate  
Finance and Corporate Branch Environ Canada  
335 River Road Ottawa Ontario  
K1A-0H3

E-mail: [carl.carroll@ec.gc.ca](mailto:carl.carroll@ec.gc.ca)

**Subject: Submission of the 2010 Annual Report for the “Eureka Weather Station” Project; Licence No. 3BC-EUR0611**

---

Dear Mr. Carroll;

The Nunavut Water Board (“NWB”) has completed a technical review of the 2010 Annual Report for the above-mentioned Project that was received on March 19, 2011.

The Eureka wastewater lagoon 2010 sampling identified Total Suspended Solids (TSS), pH, iron and manganese exceeding the CCME’s Canada-wide Strategy for the Management of Municipal Wastewater Effluent (2009) and Guidelines for the Discharge of Municipal Wastewater in the Northwest Territories (1992) that are referenced as the criteria to be used to assess compliance. These parameters exceeded the guidelines in 2009 as well.

For all of these parameters, the causes of elevated levels should be identified, and actions should be taken to bring the wastewater lagoon effluent concentrations in compliance with guidelines.

Should you have any further questions, please feel free to contact the undersigned at (867) 360-6338 or [k.kharatyan@nunavutwaterboard.org](mailto:k.kharatyan@nunavutwaterboard.org), at your earliest convenience.

Yours truly,

*Original signed by:*

Karen Kharatyan  
Technical Advisor

cc: Distribution List – Qikiqtani