



NWB Tools

Ida Porter <ida.porter@nwb-oen.ca>

NWB Water Licence No. 8BC-FOD1828, Item D.2. Addendum

Karlette Tunaley <Ktunaley@tlaconsultants.ca>

Thu, Jul 19, 2018 at 9:05 PM

To: Ida Porter <ida.porter@nwb-oen.ca>

Hello Ida

The email below can also be saved to the public registry with the SCP. I will draft the letter of acceptance and send to you tomorrow

Thank you
Karlette

Sent from my iPhone

On Jul 18, 2018, at 3:36 PM, Wyman, William <william.wyman@raytheon.com> wrote:

Hello Karlette,

Apologies for not explicitly stating the following earlier:

1. The “POL Spill Kit” is used to respond to bulk fuel spills at FOX-3. The kit is stored in the Warehouse B13A (as per the site description s.25.36.11), the location of the warehouse is shown on the site map in the description on page 14 of the site description); and
2. As per table 25.36-6 of the site description most of the fuel tanks and the majority of the fuel volume is stored at the summit site. Most of the site activity takes place at the summit site. This is where the majority of the equipment is, so this is where the HAZMAT and Waste HAZMAT is stored.

The response time for spill response is minimized because the spill kit is stored at the site summit, the same as the majority of the fuel on-site as well as HAZMAT and Waste HAZMAT.

Please let me know if require this information in a different format, or if you require any additional information.

Regards,

Will

<image001.png>

[Quoted text hidden]
[Quoted text hidden]
[Quoted text hidden]
[Quoted text hidden]

William Wyman

Environmental Services Officer
North Warning System
EHSS
Intelligence, Information and Services
Raytheon Canada Limited

+1-613-787-3655 (office)
+1-613-298-5123 (cell)
william.wyman@raytheon.com

Suite 3000
400 Cooper Street
Ottawa, On, K2P 2H8, Canada
www.raytheon.com

Visit the [EHSS webpage](#) for more information. Click [here](#) to find your EHSS professional.