



Nunavut Regional Office
P.O. Box 100
Iqaluit, NU, X0A 0H0

Your file - Votre référence
NWB file #: 8BW-KUG ----
Our file - Notre référence
File # / CIDMS #:

Aug 15, 2008

Phyllis Beaulieu
Manager of Licensing
Nunavut Water Board
P.O. Box 119
Gjoa Haven, NU X0A 1J0

**Re: 8BW-KUG---- Sub-river Aquifer Drilling Project - Community and
Government Services-GN – New Water License**

Please be advised that Indian and Northern Affairs Canada (INAC) has completed a review of a New Type B Water License Application for Community and Government Services-GN's Sub-river Aquifer Drilling Project. All associated documents related to this license are posted on your ftp site under 8BW-KUG---- were included in my review.

Project Description:

File #: 8BW-KUG----
Project: Sub-river Aquifer Drilling Project
Location: Latitude: 67°49'25"N; Longitude: 115°5'5"W
Purpose: Drilling for Potable Water
Type: "B"

As a result of the review INAC recommends that the Nunavut Water Board impose standard conditions suitable for this size of project and consider the following comments when approving this water license application.

Recommendations:

1 - The Spill Contingency Plan should clarify that all fuel catches will be located above the high mark of any water body. Further, secondary containment, such as a self-supporting berm, is recommended when storing barreled fuel on-site.

2 - The Response Action, of the Spill Contingency Plan should make reference to the Nunavut Spill Report Line and include a copy of the Nunavut Spill Report Form. This form can be obtained from the Nunavut Water Board public registry at <http://www.nunavutwaterboard.org>. Please note that the 24-

hour Spill Report Line telephone number is (867) 920-8130 and facsimile number is (867) 873-6924. Furthermore, INAC requests the proponent report all spills to Peter Kusugak, INAC Manager of Filed Operations, phone: 867-975-4295, fax 867-975-6445 as well as the Nunavut Spill Report Line.

Should you have any questions or comments, please do not hesitate to contact me at (867) 975-4738 or by email at Culla@ainc-ianc.gc.ca.

Sincerely,

Original Signed By

Andrea Cull
Water Management Specialist

Cc: Kevin Buck- Water Resources Manager- INAC